

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7080-0067:038 Page 1 of 1

CATEGORY: Halogenated Extinguishing Systems

LISTEE: Siemens Building Technologies/Cerberus Division, 8 Fernwood Rd, Florham Park,
NJ 07932 Contact: Peter Pawchak (973) 593-2662

DESIGN: Models H125, H250, HL250, H350, HL350, H600 and HL600. Total flooding Halon 1301.
Rebuilt models are designated by an "R" in the model number and are otherwise as
described herein. Cylinders may be discharged manually, electrically or pneumatically.
Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and
ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number and FM or UL label.

APPROVAL: Listed as halogenated extinguishing system. Electrical release requires manufacturer's
HC-35 or RM-30U/-30RU or HC-35 release module, which must be integrated with listed
System 3 control unit (CSFM Listing No. 7165-0067:035) or CP-2H, CP-2HA or CP-2HR
control unit (CSFM Listing No. 7165-0067:120) for releasing service or SPX-1 control
unit (CSFM Listing No. 7165-0067:120) which must be integrated with the Model XL3 (CSFM
Listing No. 7165-0067:104) control unit. May be used with Models MH51, MH57, MH501 or
MH51X pull stations (CSFM Listing No. 7150-0067:036).



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager